



Wood Gasification Boiler

Test standards **UL391,2523, CSA B366.1, ETLM78-1**

Model **Effecta Lambda 25/35/60**

Manufacture **Effecta Energy Solutions AB, Sweden**

Distributor **Up North Alternative Energy Solutions LCC
3906 Old State Rd, East Jordan MI 49727
888-536-2313
www.upnorthenergy.com**

Efficiency (%) **90**

Fuel **Cord Wood**

Maximum working pressure (PSI) **21**

Maximum tested pressure (PSI) **30**

Electrical rating **230V ~50/60Hz**

Electrical rating with a converter **115V ~50/60Hz**

Flooring **Noncombustible**

Sides Clearance **12"**

Rear Clearance **18"**

Front Clearance **24"**

Top Clearance **18"**

DO NOT CONNECT THIS TO A CHIMNEY FLUE SERVING ANOTHER APPLIANCE.

Serial #
See Manufacture label

Certified by:
Guardian Fire Test Laboratories Inc
ISO 17025-AT1247
www.firetesting.com